



NOTES:

1. J-BOLT DIAMETER:
 - PIPE DIAMETER LESS THAN OR EQUAL TO 6": 7/8", 8" PIPE: 1", 10" = 1-1/4".
 - PIPE DIAMETER GREATER THAN 12": 1-1/2".
2. TIGHTEN TOP NUTS TO TENSION BOLTS.
3. TIGHTEN LOWER NUTS TO COMPRESS CLAMP SNUG.

PIPE CLAMP & ANCHOR RODS FOR CONCRETE BLOCKING

WATER STANDARD DETAIL
W-7

**UNION HILL
WATER ASSOCIATION**

SCALE: NTS	DATE: OCT 22, 2018
R:\CAD\DETAIL\AUTOCAD\UHWA\W-7 PIPE CLMP	