



SINGLE WATER SERVICE PROFILE

NTS

PARTS LISTS FOR 1" SERVICE

MANUFACTURE	DESCRIPTION	PART NUMBER	SIZE/DESCRIPTION
ROMAC	SERVICE SADDLE WITH STAINLESS DOUBLE STRAPS	202S WITH 1" IPT	1" IPT
FORD METER BOX	BALL CORP STOP	F1101-4-G-NL	1" IPT X 1" IPS-PE GRIP JOINT
N/A	POLY PIPE	N/A	1" IPS PE SIDR 7 250 PSI
FORD METER BOX	STRAIGHT COUPLING	C86-44-G-NL	1" IPT X 1" IPS-PE GRIP JOINT
FORD METER BOX	STAINLESS INSERT	#53 OR #72	1" IPS PE INSERT
FORD METER BOX	METER SETTER	VBH74-12W-NL	1" W/ DUAL CONNECTIONS/BALL VALVE AND SINGLE CHECK
N/A	BRASS 90 ELBOW	N/A	1"X 1" (NO LEAD)
N/A	SOLID COPPER WIRE COATED BLUE	N/A	14 GAUGE
CARSON	PLASTIC METER BOX WITH METAL READING LID	1324	12" DEEP - LANDSCAPE AREA
CARSON	PLASTIC METER BOX WITH SOLID METAL LID AND 2" HOLE FOR READER PAD	1324	12" DEEP - DRIVEWAY AREA

- NOTES:
1. ALL BRASS FITTINGS TO BE NO LEAD APPROVED FOR POTABLE WATER SYSTEMS.
 2. WATER METER TO BE INSTALLED BY UNION HILL WATER ASSOCIATION STAFF.
 3. DOUBLE WATER SERVICES - NEED TO INSTALL 1-1/2" PLASTIC LINE BETWEEN AND UNDER METER BOXES.
 4. MEET KING COUNTY ROAD REQUIREMENTS FOR RESTORATION.

1" WATER SERVICE

**UNION HILL
WATER ASSOCIATION**

**WATER STANDARD DETAIL
W-23**

SCALE: NTS DATE: JUNE 10, 2022

R:\CAD\DETAIL\AUTOCAD\UHWA\W-23 1IN W SVC