



NOTES:

1. ALL PARTS SHALL BE CAST OR DUCTILE IRON AND COATED WITH ASPHALTIC VARNISH.
2. STAR PIPE PRODUCTS 940 18" VALVE BOX WITH VBST940L WATER LID AND 36" VALVE BOX BOTTOM (BASE SECTION).

## VALVE BOX INSTALLATION

UNION HILL  
WATER ASSOCIATION

WATER STANDARD DETAIL  
W-21

SCALE: NTS | DATE: NOV 6, 2018

R:\CAD\DETAIL\AUTOCAD\UHWA\W-21 VLV BOX